



- Notes:
1. No Galvanized or
  2. Iron pipe prior to meter
  3. Distance A shall be 10 times the pipe diameter
  4. Distance B shall be 5 times the pipe diameter
  5. All fittings shall be restrained

REV.	DATE	BY
1	11-12-24	MF

**SUMMIT WATER  
DISTRIBUTION CO.**

**Commercial Meter  
Connection**